

Lehigh County Authority Annual Water Quality Report 2021

North Whitehall Division
PWSID: 3390055

Este informe contiene informacion muy importante sobre su agua potable. Traduzcalo o hable con alguien que lo entienda bien.

LCA Commitment to Safe Drinking Water

LCA is a public, nonprofit water and sewer utility dedicated to a single mission – to provide continually improved, affordable, reliable and sustainable services to our customers.

Continuous improvement comes from our ongoing participation in programs and associations such as the Partnership for Safe Water program, Lehigh Valley Water Suppliers, American Water Works Association, the PA-DEP Source Water Protection Technical Assistance Program and the Pennsylvania Association of Accredited Environmental Laboratories. It also comes from our professional staff of water plant operators, laboratory technicians, customer service personnel and distribution system operators who provide the highest quality service possible every single day.

This report contains detailed information about your water quality. As you review this information, please feel free to contact LCA to ask questions and learn more about our commitment to our customers. Thank you!

What's inside this report?

- About Your Water System 4
- Why This Report Is Important! 5
- 2021 Water Quality Test Results 6
- What does this report mean? 14
- Any violations in 2021? 15
- What's NOT in your water? 16
- Other Important Information 17
- A Note From EPA 22
- Water Hardness, pH & Other Useful Info 24
- Protecting Your Drinking Water 26
- How to Reach LCA & Get Involved 28

About Your Water System

Service Area: The villages of Neffs, Schnecksville and Orefield in North Whitehall Township.

Number of Customers: 969 properties served.

Water Supply: Three wells plus an interconnection with the Northampton Borough Municipal Authority (NBMA) system, which draws water from the Lehigh River and the Spring Mill Dam. These sources combine to produce an average of 603,234 gallons per day.

Water Treatment: Water from LCA's wells is disinfected with chlorine and treated to reduce manganese that is naturally occurring in the area. NBMA treats its water at a full-scale water filtration plant. For more information on their sources of water, treatment techniques or water quality monitoring, please contact 610-262-6711.

NOTE: As of 1/22/2021, LCA discontinued use of its 3 wells, and all water supplied after this date is drawn from the NBMA water system.

Why this report is important!

The information contained in this report may be especially important for some groups of people, such as the elderly, people with compromised immune systems and infants. If you are viewing this report, but the water LCA provides is actually provided to tenants, patients, customers or employees who use your property, please make a copy of this report available to them as well.
Thank you!

Water Quality Test Results

Abbreviations & Definitions

| | |
|---------------------|---|
| MCL: | Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs (definition below) as feasible using the best available treatment technology. |
| MCLG: | Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MinRDL: | Minimum Residual Disinfectant Level. The minimum level of residual disinfectant required at the entry point to the distribution system. |
| MaxRDL: | Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| MaxRDLG: | Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MaxRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination. |
| AL: | Action Level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| TT: | Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water. |
| mg/L: | Milligrams per liter. |
| NTU: | Nephelometric turbidity units (measure of water's cloudiness) |
| pCi/L: | Picocuries per liter (a measure of radiation). |
| ppm: | Parts per million (equal to milligrams per liter). |
| ppb: | Parts per billion. |
| ug/L: | Micrograms per liter. |
| N/A: | Not applicable. |
| ND: | Not detected. |
| < or > | < = Less than. > = Greater than. |

Water Quality Test Results

Entry Point Disinfectant Residual

| Contaminant Name | MCL (Maximum Allowed) | MCLG (Goal) | LCA's Water Test Results | Range of LCA's Test Results | Sample Date | Pass or Fail? | Typical Source |
|--------------------------------------|-----------------------------|----------------|------------------------------------|--------------------------------|----------------|------------------|--|
| Chlorine (as Cl ₂) (ppm) | MinRDL = 0.40 | N/A | Lowest Detected Level = 1.27 | 1.27 – 2.39 | 2021 | Pass | Water additive used to control microbes |

Water Quality Test Results

Chemical Contaminants

| Contaminant Name | MCL (Maximum Allowed) | MCLG (Goal) | LCA's Water Test Results | Range of LCA's Test Results | Sample Date | Pass or Fail? | Typical Source |
|---|--------------------------|----------------|-----------------------------------|-----------------------------------|----------------|---------------------|--|
| Chlorine (as Cl ₂) (ppm) | MaxRDL = 4 | MaxRDLG = 4 | 1.60 | 1.04 – 1.60 | 2021 | Pass | Water additive used to control microbes |
| Total Trihalomethanes (ppb) | 80 | N/A | 55.5 | 24.9 – 37.1 | 2021 | Pass | By-product of drinking water chlorination |
| Haloacetic Acids (ppb) | 60 | N/A | 31.1 | 22.9 – 35.7 | 2021 | Pass | By-product of drinking water disinfection |
| Antimony (ppb) | 6 | 6 | 0.7 | ND – 0.7 | 2018 | Pass | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder |
| Barium (ppm) | 2 | 2 | 0.066 | 0.019 – 0.066 | 2018 | Pass | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |

Water Quality Test Results

Chemical Contaminants (cont'd)

| Contaminant Name | MCL (Maximum Allowed) | MCLG (Goal) | LCA's Water Test Results | Range of LCA's Test Results | Sample Date | Pass or Fail? | Typical Source |
|------------------|--------------------------|----------------|-----------------------------------|-----------------------------------|----------------|---------------------|--|
| Fluoride (ppm)* | 2 | 2 | 0.48 | N/A | 2021 | Pass | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Nickel (ppm)** | N/A | N/A | 0.002 | 0.001 – 0.002 | 2021 | N/A | Erosion of natural deposits |
| Nitrate (ppm) | 10 | 10 | 4.77 | 1.17 – 4.77 | 2021 | Pass | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |

* Fluoride: NBMA adds fluoride to its drinking water, but LCA does not add fluoride to its well water. Since your water is blended from these sources, the amount of fluoride will vary, but will not exceed the level shown in this report. NOTE: as of 1/22/2021 LCA is no longer using the 3 wells, and all water is coming from NBMA and therefore fully fluoridated.

** Nickel: Although we are required to test for Nickel, the EPA has rescinded the MCL and MCLG on the amount of Nickel allowed in drinking water.

Water Quality Test Results

Lead & Copper Testing

| Contaminant Name | MCL (Maximum Allowed) | MCLG (Goal) | LCA's Water Test Results | Range of LCA's Test Results | Sample Date | Pass or Fail? | Typical Source |
|------------------|-----------------------------|----------------|-----------------------------|--------------------------------|----------------|------------------|--|
| Copper (ppm) | AL = 1.3 | 1.3 | 0.03 | All samples were < AL | 2019 | Pass | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives |

Water Quality Test Results

Radioactive Contaminants

| Contaminant Name | MCL (Maximum Allowed) | MCLG (Goal) | LCA's Water Test Results | Range of LCA's Test Results | Sample Date | Pass or Fail? | Typical Source |
|------------------------|-----------------------------|----------------|-----------------------------|--------------------------------|----------------|------------------|---|
| Alpha Emitters (pCi/L) | 15 | 0 | 6.01 | ND – 6.01 | 2018 | Pass | Decay of natural and manmade deposits |

Water Quality Test Results

Other Contaminants

| Contaminant Name | MCL (Maximum Allowed) | MCLG (Goal) | LCA's Water Test Results | Range of LCA's Test Results | Sample Date | Pass or Fail? | Typical Source |
|----------------------------|--|-------------|--------------------------|-----------------------------|-------------|---------------|---------------------------------------|
| Turbidity (NTU) | $\frac{TT = 1}{TT = \text{at least 95\% of monthly samples} \leq 0.3 \text{ NTU}}$ | 0 | $\frac{0.165}{100\%}$ | N/A | 2021 | Pass | Soil runoff |
| Total Organic Carbon (ppm) | TT | N/A | 0.90 | 0.71 – 1.22 | 2021 | Pass | Naturally present in the environment. |

Water Quality Test Results

Unregulated Contaminant Monitoring

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

| Contaminant Name | Reported Level (Average) | Range of Results |
|------------------|--------------------------|------------------|
| Manganese (ppb)* | 2.08 | ND – 5.5 |
| HAA6Br (ppb) | 6.82 | 4.20 – 8.79 |
| HAA9 (ppb) | 36.88 | 24.11 – 48.07 |

** Well 106 tested on 1/14, had a Manganese result of 320 ppb. The well was removed from service.*

All results are from the 2018-2020 Unregulated Contaminant Monitoring Rule 4 (UCMR4) testing.

What does this report mean?

The information in this report shows only those substances that were detected in your water. All of them “passed” because they fall within acceptable limits for health and safety as determined by state and federal regulations. These regulations are put in place to protect the public’s health, and we are pleased to show that our water met these standards in 2021!

Any violations in 2021?

Notice: 2021 Reporting Violation

LCA is required to monitor your drinking water for specific contaminants and treatment chemicals on a regular basis. Results of regular monitoring are an indicator of whether your drinking water meets health standards. We are required to submit the results of all water tests to the state within the first 10 days of the month following the month in which the water is tested. For the month of July 2021, a Coliform bacteria test result was not submitted to the state by August 10th. The sample was taken, tested and passed the requirements, but was not reported in time. This is a violation of the Pennsylvania Safe Drinking Water regulations.

This monitoring violation occurred due to a result not being transmitted to the state reporting system. The sample was taken and tested, but not reported, which has been corrected through additional training.

Immediately of learning of the violation, the total coliform result was reported.

What's NOT in your water?

In addition to the substances shown in this report, LCA tests your water for many other substances which were NOT detected in your water. These tests are routinely conducted according to schedules and procedures outlined in state and federal regulations for safe drinking water.

Substances LCA tests for include:

Microbiological Contaminants

Radioactive Contaminants

Inorganic Contaminants

Disinfection By-Products

Volatile Organic Contaminants

Synthetic Organic Contaminants

With the exception of those listed in the charts in this report, none of the substances we have tested for have been detected in your drinking water. For detailed information about our water quality monitoring program, please give us a call at 610-398-1444 any time with your questions.

Other Important Information

Water Testing Frequency

The monitoring results shown in this report includes information from calendar year 2021. Annual testing is not required for all contaminants. Some are on multi-year cycles based on schedules determined by state and federal regulations. We also test for some contaminants such as total coliform and chlorine many times throughout the year as results may change as environmental conditions change.

Other Important Information

NBMA Water

Because LCA purchases your water from the Northampton Borough Municipal Authority (NBMA), some of the water quality monitoring information provided in this report was collected by NBMA. LCA monitors the distribution system that delivers the water to your property and conducts tests to ensure that your drinking water quality is maintained as it travels through the pipes to your property, as well as monitoring the well water we produce. If you would like more information about monitoring schedules or specific test results, please call our office at 610-398-1444 or NBMA at 610-262-6711.

Other Important Information

Nitrates in Drinking Water

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

Other Important Information

Cryptosporidium

Cryptosporidium is a microbial parasite commonly found in surface water, and NBMA has monitored for it in both the source water and treated water prior to distribution to customers. NBMA's monitoring concludes that Cryptosporidium is present in the river source, but is **not** detected in their finished water. At present, there is no evidence that customers should be concerned with Cryptosporidium.

Customers should be aware that cryptosporidium is capable of causing a disease called cryptosporidiosis. Symptoms include diarrhea, abdominal cramping and nausea. Healthy individuals usually overcome the illness in a few weeks. However, immuno-compromised individuals are at greater risk of developing serious, chronic illness. These people should consult a physician to discuss precautions to avoid infection. Cryptosporidium must be ingested to develop disease, and it may be spread through means other than drinking water.

Other Important Information

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LCA is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

A Note From EPA

Where drinking water contamination comes from, and how EPA protects public health

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include microbes, organic or inorganic chemicals, pesticides and herbicides or radioactive materials.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

A Note From EPA (cont'd)

Where drinking water contamination comes from, and how EPA protects public health

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Water Hardness, pH & Other Useful Info

Water “hardness” is a measure of the mineral content in your water. These minerals, such as calcium and magnesium, are essential to human health and do not need to be removed from your drinking water. However, some customers prefer to remove these minerals with a water softener to avoid mineral deposits on faucets and other fixtures.

Hardness Scale:

0 - 5 grains per gallon = Soft Water

6 - 10 grains per gallon = Moderately Hard Water

> 11 grains per gallon = Hard Water

Water Hardness, pH & Other Useful Info

Secondary Contaminant Analysis

Secondary contaminants are associated with the aesthetic qualities of drinking water, such as taste, smell, color and formation of deposits on plumbing fixtures. When a secondary contaminant MCL is exceeded, you may notice a change in the color, smell or taste of your tap water.

| Contaminant Name | MCL | Your Water – Average |
|------------------------------------|-----------|----------------------|
| Alkalinity (ppm) | N/A | 24 |
| Calcium (ppm) | N/A | 13 |
| Iron (ppm) | 0.3 | Non-Detect |
| Magnesium (ppm) | N/A | 3.5 |
| Manganese (ppm) | 0.05 | Non-Detect |
| pH (standard units) | 6.5 – 8.5 | 7.15 |
| Sodium (ppm) | N/A | 13.8 |
| Total Dissolved Solids (ppm) | 500 | 104 |
| Total Hardness (grains per gallon) | N/A | 4 |

Protecting Your Drinking Water

The Pennsylvania Department of Environmental Protection (PA-DEP) completed an initial Source Water Assessment of the Lehigh River source, and LCA's groundwater sources that supply water to your system in 2004. An update to the Lehigh River assessment was completed on behalf of NBMA in 2012 and LCA in 2020 through PA-DEP's Source Water Protection Technical Assistance Program. Public meetings were held in 2012 to review the assessment, and completed reports are available for review by LCA, Northampton Borough Municipal Authority, and local planning agencies.

The assessment found that Northampton's and LCA's sources of water are located within residential, commercial and industrial areas and, therefore, are susceptible to potential sources of contamination from related activities. Examples include leaking underground storage tanks, wintertime road salt applications and household activities such as lawn fertilizing and improper disposal of household hazardous wastes. Please contact LCA if you are interested in learning more about the Source Water Protection plan.

A summary of the report is available by contacting LCA, and additional information is available on the PA-DEP web site at www.dep.state.pa.us (use Keyword "Source Water Assessment and Protection").

Protecting Your Drinking Water

Here are a few ideas about how you can help:

Don't Dump: Anything you put on the ground or down a storm drain can make its way into our groundwater or other water sources. Contact the Lehigh County Office of Solid Waste at 610-799-4177 to find out how to dispose of household hazardous wastes.

Lawn Care: Use only as much fertilizer as your lawn or garden really needs, and be sure to pick up after your pets!

Care for Your Car: Oil spots left on driveways and parking lots can wash away with the rain and will end up back in the environment.

Report Spills: Call 9-1-1 if you witness accidental or intentional dumping of unknown substances into our environment!

Visit our interactive **source water protection** web page to learn how you can help protect drinking water! <https://www.lehighcountyauthority.org/source-water-protection/>

Got Questions?

How to reach LCA:

Please contact Lehigh County Authority at 610-398-1444, or visit us online at www.lehighcountyauthority.org.

Board meetings are open to the public and can also be viewed live online! Please visit us online for a meeting schedule and agendas, to view a current or past meeting, or to learn more about LCA projects and programs.